

LEGEND

- 100 Ø C.I. LINE
 - 50 Ø G.I. DELIVERY LINE
- NOTES:-
- (1) DEPTH OF WATER SUPPLY LINES SHALL BE 750mm FROM ROAD LEVEL.
 - (2) MINIMUM SIZE OF FIRST INSPECTION CHAMBER FOR SEWERAGE SHALL BE 900 x 800mm WITH 450mm DEPTH.
 - (3) DISTANCE BETWEEN TWO MANHOLES SHALL NOT EXCEED 20.0mtr. C/C
 - (4) HEAVY DUTY CIRCULAR SOLID TYPE MANHOLE COVERS FRAME OF STEEL FIBRE REINFORCED CONCRETE (ISI MARKED) SHALL BE USED.
 - (5) HORIZONTAL GRATING CHAMBERS SHALL BE PROVIDED AT EVERY INTERSECTION OF DRAIN AND IT SHOULD NOT BE PROVIDED GREATER THAN 18.0mtr. APART.
 - (6) SEWER PIPE AND SWD PIPE SHALL BE COVERED WITH R.C.C. (1 : 3 : 6) UPTO HAUNCHES.
 - (7) THE DEPTH OF STARTING MANHOLE OF 150mm Ø SEWER LINE SHALL BE 0.76mtr. FROM ROAD LEVEL.
 - (8) THE DEPTH OF ROAD GULLY CHAMBER AT START SHALL BE 0.6mtr. OF 300mm Ø SWD LINE.
 - (9) THE SIZE OF ROAD GULLY CHAMBER AT START ON 150mmØ SWD LINE SHALL BE 300 x 300mm AND 400mm DEEP.
 - (10) S.W.D. CHAMBERS ON 300Ø LINE SHALL BE 450 x 500mm & 600mm DEEP.



45 M WIDE ROAD

PROJECT:-
 GROUP HOUSING FOR
M/S V.N. INFRA TECH PVT. LTD.
 PLOT NO- 11/GH-11, SECTOR-11,
 AT VRINDAVAN YOJNA NO-3, LUCKNOW. (U.P.)

SIGNING AUTHORITY **GUARD ROOM DETAIL**

ARCHITECT'S SIGN

SUBMISSION DRAWING


DRG. TITLE:- LAYOUT PLAN
 SHOWING WATER SUPPLY LINE

SCALE:-1:250

DRG. NO.: 14

DLT.BY:- NEELAM

DATE:-10/08/2016



ARCHITECTS:-
 P. N. ANDLEY B.ARCH. A.J.J.A.
ANDLEYS ASSOCIATES PVT. LTD.
 ARCHITECTS ENGINEERS PLANNERS
 39 HOUSING SOCIETY N.D.S.E.-I NEW DELHI - 110049